



BUREAU  
VERITAS

Bureau Veritas Certification

# BVC CERTIFICATE OF PRODUCT

Certificate nb: ES119856

In application of the BVC procedure for the certification of "Mobile fire extinguishers", BVC has established that the products:

## MOBILE FIRE EXTINGUISHERS

The characteristics are detailed in the attached annex

Made by the manufacturer:

**ELITEX PROTECTION, S.L.**

In its factory located in:

CTRA N-320 (ALBACETE-CUENCA), KM 133,5-16003 CUENCA (SPAIN)

They are submitted by the manufacturer to the test and Factory Production Control, and submitted to the evaluation, the Type Tests, and Factory Production Control by Bureau Veritas Certification and performs the continuous surveillance, assessment and approval of the Factory Production Control described in the harmonized standard:

**UNE-EN 1866-1:2008**

This certificate remains valid while the product, the production conditions of the factory or the same FPC have not changed significantly.

Initial date of issue: 2021, July 19<sup>th</sup>

Expiration date: 2024, July 18<sup>th</sup>



Mónica Botas  
Certification Manager

Bureau Veritas Iberia, S.L., Edificio Caoba. C/ Valportillo Primera 22-24  
28108 Alcobendas (MADRID)







BUREAU  
VERITAS

Bureau Veritas Certification

## ANNEX TO CERTIFICATE N° ES119856

Brand	Model	Pressurization type and PS	Extinguisher agent (type and load)	Temperature range	Effectiveness
ELITEX	25P ELITE UNE	Permanent 17,5 bar	Powder ABC 25kg	-20 / +60	A IV B
ELITEX	50P ELITE UNE	Permanent 17,5 bar	Powder ABC 50kg	-20 / +60	A IV B

Rev: 0

Date: 2021, July 19<sup>th</sup>



Mónica Botas  
Certification Manager

Bureau Veritas Iberia, S.L., Edificio Caoba. C/ Valportillo Primera 22-24  
28108 Alcobendas (MADRID)

