



BUREAU  
VERITAS

Bureau Veritas Certification

## BVC PRODUCT CERTIFICATE

Certificate No: ES119856

In application of the BVC procedure for the certification of "Mobile Fire Extinguishers", BVC has established that the products:

### MOBILE FIRE EXTINGUISHERS

with the designation and characteristics listed in the technical annex attached to this certificate

Manufactured by:

**ELITEX PROTECTION, S.L.**

Production Center:

CTRA. N-320 (ALBACETE - CUENCA) - KM 133,5  
16003 - CUENCA (SPAIN)

are submitted to tests and factory production control by the manufacturer and by Bureau Veritas Certification, to the evaluation, type test, production control and the continuous surveillance of the factory production control, according to the established requirements of the standard:

**UNE-EN 1866-1:2008**

This certificate remains valid as long as the product, the manufacturing conditions and the production control have not been modified significantly.

Initial date of issue: 2021 / 07 / 19  
Date of update: 2024 / 06 / 19  
Expiration date: 2027 / 07 / 18



**Mónica Botas**  
Certification Manager





BUREAU  
VERITAS

Bureau Veritas Certification

## ANNEX TO CERTIFICATE No: ES119856

Brand	Model	Pressurization Type and PS	Extinguisher Agent (Type and Load)	Temperature Range	Effectiveness	Date
ELITEX	25P ELITE UNE	Permanent 17,5 bar	Powder ABC 25kg	-20 / +60	A IV B	2021 / 07 / 19
ELITEX	50P ELITE UNE	Permanent 17,5 bar	Powder ABC 50kg	-20 / +60	A IV B	2021 / 07 / 19

*Revision: 0*

*Revision date: 2021 / 07 / 19*



**Mónica Botas**  
Certification Manager

