



BUREAU
VERITAS

Bureau Veritas Certification

BVC PRODUCT CERTIFICATE PORTABLE FIRE EXTINGUISHERS

Certificate No:ES046108

In application of the BVC procedure for the certification of "Portable fire extinguishers", BVC has established that the products:

PORTABLE FIRE EXTINGUISHERS

with the designation and related characteristics in the technical annex attached to this certificate,

Comply with standard:

UNE-EN 3-7:2004/A1:2008

Manufacturer:

ELITEX PROTECTION, S.L

Production centre:

CTRA N-320 (ALBACETE-CUENCA) KM 133,5
16003 - CUENCA (SPAIN)

The products are subjected by the manufacturer to the factory production tests and control, and by Bureau Veritas Certification to the type test and production control and the continuous monitoring of the factory production control in accordance with the requirements established in standard UNE-EN 3-10:2010.

The certificate remains valid while the product, the manufacturing conditions and production control have not significantly changed.

First issue date: 2012 / 11 / 16
Date of update: 2024 / 08 / 14
Expiry date: 2027 / 11 / 15



Mónica Botas
Certification Manager

Bureau Veritas Iberia, S.L., Edificio Caoba. C/ Valportillo Primera 22-24
28108 Alcobendas (MADRID)





BUREAU
VERITAS

Bureau Veritas Certification

ANNEX TO CERTIFICATE n°: ES046108

Brand	Model	Pressurization Type and PS	Extinguishing Agent (Type and Charge)	Operating Temperature	Effectiveness	Date
ELITEX PROTECTION	1P ELITE	Permanent 17,5 bar	Powder ABC 1kg	-20 / +60	5 A 21 B	21.08.06
ELITEX PROTECTION	2P ELITE	Permanent 17,5 bar	Powder ABC 2kg	-20 / +60	8 A 34 B	21.08.06
ELITEX PROTECTION	3P ELITE	Permanent 17,5 bar	Powder ABC 3kg	-20 / +60	13 A 89 B	21.08.06
ELITEX PROTECTION	2 ESPUMA F ELITE	Permanent 17,5 bar	Water+AFFF 2L	+5 / +60	5 A 34 B 25 F	21.08.06
ELITEX PROTECTION	6P ELITEX PLUS	Permanent 17,5 bar	Powder ABC 6kg	-20 / +60	34 A 233 B	21.08.06
ELITEX PROTECTION	6P ELITEX	Permanent 17,5 bar	Powder ABC 6kg	-20 / +60	27 A 183 B	21.08.06
ELITEX PROTECTION	6 ESPUMA ELITEX	Permanent 17,5 bar	Water+AFFF 6L	+5 / +60	27 A 233 B	21.08.06
ELITEX PROTECTION	6 ESPUMA ELITEX PLUS	Permanent 17,5 bar	Water+AFFF 6L	+5 / +60	34 A 233 B	21.08.06
ELITEX PROTECTION	6 ESPUMA F ELITEX	Permanent 17,5 bar	Water+AFFF 6L	+5 / +60	27 A 233 B 75 F	21.08.06
ELITEX PROTECTION	6 ESPUMA F ELITEX PLUS	Permanent 17,5 bar	Water+AFFF 6L	+5 / +60	34 A 233 B 75 F	21.08.06
ELITEX PROTECTION	9P ELITEX	Permanent 17,5 bar	Powder ABC 9kg	-20 / +60	43 A 233 B	21.08.06
ELITEX PROTECTION	2 CO2 ELITEX	Permanent 58 bar	CO2 2kg	-20 / +60	34 B	21.08.06
ELITEX PROTECTION	5 CO2 ELITEX	Permanent 58 bar	CO2 5kg	-20 / +60	89 B	21.08.06
ELITEX PROTECTION	6 ESPUMA ELITEX CERO FLUOR	Permanent 17,5 bar	Water+Additive 6L	+5 / +60	27A 144B	24.01.05

Revisión: 9

Revisión date: 2024 / 08 / 14



Mónica Botas
Certification Manager

Bureau Veritas Iberia, S.L., Edificio Caoba. C/ Valportillo Primera 22-24
28108 Alcobendas (MADRID)

